



# Avon Lake Regional Water

Serving the region,  
protecting our resource.

## Supplemental Notification of CSO

Date: 25-Aug Lake Erie receives the discharge  
Time: 1015 Permit # 3PD00003

Inspector: JP

Initial Notification sent: 8/25/2023

Start time of CSO discharge: 2107 8-23-23

CSO Outfall Information: Center Road Pump Station

Outfall Number: 17

Flow observed: Indicated by Observation and metering

How full a pipe: Over 3/4 full

Impacted areas: Lake Erie from Miller Road to Lear Road

Veteran's Memorial Park  Yes

Avon Lake Boat Club  Yes

Lake Erie  Yes

Miller Road Park  No

End time of CSO discharge: 0520 8-24-23

End time of rain event: Same

Estimated Volume of discharge: 3.5 MG

Questions can be directed to Jeremy Pijor 440-897-7263

Precipitation: Prolonged heavy rainfall.

Note:

Extreme amount of precipitation over an extended period of time.

4+ inches per NWS

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_