



Avon Lake Regional Water

Serving the region,
protecting our resource.

Supplemental Notification of CSO

Date: 23-Aug Lake Erie receives the discharge
Time: 0600 through 0730 Permit # 3PD00003

Inspector: SCB

Initial Notification sent: 0902 8/22/2019

Start time of CSO discharge: ~0600

CSO Outfall Information: All outfalls

Outfall Number: _____

Flow observed: Indicated by modeling/Observation

How full a pipe: _____

Impacted areas: Lake Erie from Miller Road to Lear Road

Veteran's Memorial Park Yes

Avon Lake Boat Club Yes

Lake Erie Yes

Miller Road Park Yes

End time of CSO discharge: ~ 0730 8/22/2019

End time of rain event: Same

Estimated Volume of discharge: ~0.5 MGD

Questions can be directed to Steve Baytos at 440-610-7519.

Precipitation: ~ 1.36 inches of rainfall

Note:

Rain fell in a short time period.

overflows were brief.
