



Avon Lake Regional Water

Serving the region,
protecting our resource.

Supplemental Notification of CSO

Date: 7-Sep Lake Erie receives the discharge
 Time: 1015 Permit # 3PD00003
 Inspector: SCB
 Initial Notification sent: 9/7/2020
 Start time of CSO discharge: 1015 - 1500
 CSO Outfall Information: Center Road Lift Station
 Outfall Number: Center Road Pump Station
 Flow observed: Observation and metering
 How full a pipe: 2-Jan

Impacted areas: Vetrans Park area

- Veteran's Memorial Park Yes
- Avon Lake Boat Club Yes
- Lake Erie Yes
- Miller Road Park No

End time of CSO discharge: 1500

End time of rain event: Same

Estimated Volume of discharge: .5-1 MGD

Questions can be directed to Steve Baytos at 440-610-7519.

Precipitation: ~ 3 inches of rainfall

Note:

Large volume of precipitation in a short window of time.
